

Compliance Document for New Zealand Building Code Clause G8 Artificial Light

Prepared by the Department of Building and Housing

This Compliance Document is prepared by the Department of Building and Housing. The Department of Building and Housing is a Government Department established under the State Sector Act 1988.

Enquiries about the content of this document should be directed to:



Department of
Building and Housing

Te Tari Kaupapa Whare

Department of Building and Housing
PO Box 10-729, Wellington.
Telephone 0800 242 243
Fax 04 494 0290
Email: info@dbh.govt.nz



Sales enquiries should be directed to:
Customer Services,
Victoria University Book Centre
PO Box 12-337, Wellington, New Zealand
Telephone 0800 370 370, (04) 463 5511
Fax (04) 463 5510
Email: dbh@vicbooks.co.nz
www.vicbooks.co.nz
ISBN 0-477-01606-5

© Department of Building and Housing 2006

This Compliance Document is protected by Crown copyright, unless indicated otherwise. The Department of Building and Housing administers the copyright in this document. You may use and reproduce this document for your personal use or for the purposes of your business provided you reproduce the document accurately and not in an inappropriate or misleading context. You may not distribute this document to others or reproduce it for sale or profit.

The Department of Building and Housing owns or has licences to use all images and trademarks in this document. You must not use or reproduce images and trademarks featured in this document for any purpose (except as part of an accurate reproduction of this document) unless you first obtain the written permission of the Department of Building and Housing.

Status of Compliance Documents

Compliance Documents are prepared by the Department of Building and Housing in accordance with section 22 of the Building Act 2004. A Compliance Document is for use in establishing compliance with the New Zealand Building Code.

A person who complies with a Compliance Document will be treated as having complied with the provisions of the Building Code to which the Compliance Document relates. However, a Compliance Document is only one method of complying with the Building Code. There may be alternative ways to comply.

Users should make themselves familiar with the preface to the New Zealand Building Code Handbook, which describes the status of Compliance Documents and explains alternative methods of achieving compliance.

Defined words (italicised in the text) and classified uses are explained in Clauses A1 of the Building Code and in the Definitions at the start of this Compliance Document.

G8: Document History		
	Date	Alterations
First published	July 1992	
Amendment 1	1 July 2001	p. 2, Document History, Status p. 9, Definitions
Note: Page numbers relate to the document at the time of Amendment and may not match page numbers in current document.		

Document Status

The most recent version of this document, as detailed in the Document History, is approved by the Chief Executive of the Department of Building and Housing. It is effective from 1 July 2001 and supersedes all previous versions of this document.

People using this Compliance Document should check for amendments on a regular basis. The Department of Building and Housing may amend any part of any Compliance Document at any time. Up-to-date versions of Compliance Documents are available from www.dbh.govt.nz

New Zealand Building Code

Clause G8 Artificial Light

This Clause has been extracted from the New Zealand Building Code contained in the First Schedule of the Building Regulations 1992.

1992/150	<i>Building Regulations 1992</i>	65
FIRST SCHEDULE— <i>continued</i>		
Clause G8—ARTIFICIAL LIGHT		
Provisions	Limits on application	
OBJECTIVE		
G8.1 The objective of this provision is to safeguard people from injury due to lack of <i>adequate</i> lighting.		
FUNCTIONAL REQUIREMENT		
G8.2 Spaces within <i>buildings</i> used by people, shall be provided with <i>adequate</i> artificial lighting which, when activated in the absence of sufficient natural light, will enable safe movement.		
Requirement G8.2 shall apply to:		
(a) All <i>exitways</i> in <i>Multi-unit Dwellings, Group Dwellings and Communal Residential, Communal Non-residential, Commercial and Industrial buildings,</i>		
(b) All <i>access routes</i> except those in <i>Outbuildings and Ancillary buildings,</i> and		
(c) All common spaces within <i>Multi-unit Dwellings, Group Dwellings, and Communal Residential and Communal Non-residential buildings.</i>		
PERFORMANCE		
G8.3 <i>Illuminance</i> at floor level shall be no less than 20 lux.		
Performance G8.3 shall not apply in emergencies, for which <i>Illuminance</i> requirements are given in Clause F6 "Lighting for Emergency".		

Contents

	Page
References	7
Definitions	9
Verification Method G8/VM1	11
1.0 Illuminance	11
Acceptable Solution G8/AS1	13
1.0 Illuminance	13
Index	15

References

For the purposes of New Zealand Building Code compliance, referenced documents shall be deemed to include any amendments issued prior to the date of the Approved Document as displayed at the foot of the page on which the references are listed.

Standards Association of New Zealand

NZS 6703: 1984 Code of practice for interior lighting design

Where quoted

VM1 1.0.1

Definitions

This is an abbreviated list of definitions for words or terms particularly relevant to this Approved Document. The definitions for any other italicised words may be found in the New Zealand Building Code Handbook.

Amend 1
Jul 2001

Illuminance The luminous flux falling onto a unit area of surface.

Amend 1
Jul 2001

Reflectance The ratio of the flux reflected from a surface to the flux incident on it.

Verification Method G8/VM1

1.0 Illuminance

1.0.1 An acceptable verification method for the measurement of *illuminance* is contained in NZS 6703 Section 11.

1.0.2 Measurements shall be made on the horizontal plane at floor level. The measurements shall be made in areas unobstructed by objects likely to affect the reading. Obstructions, such as furniture shall be removed.

1.0.3 Measurements shall not be made within 500 mm of vertical surfaces. Minimum *illuminances* will generally occur furthest from the luminaire(s) and at least four measurements shall be made around each luminaire on two horizontal axes at right angles. If the layout of luminaires is symmetrical or the room is small and it is physically impossible to take the above measurements, the number of measurements may be reduced.

COMMENT:

The measurement of the minimum *illuminance* is necessary to check New Zealand Building Code compliance, or to reveal the need for maintenance or replacement in an existing installation.

1.0.4 Daylight or spill light from adjacent rooms shall be excluded, and lamps switched on and allowed to stabilize. In the case of fluorescent or discharge lighting this will be not less than 20 minutes.

1.0.5 Because accurate measurement is difficult, an installation shall be deemed to comply with the New Zealand Building Code, if the measured *illuminance* is no less than 18 lux.

Acceptable Solution G8/AS1

1.0 Illuminance

1.0.1 To provide a minimum *illuminance* of 20 lux, the total wattage required per m² of floor area is shown in Table 1.

1.0.2 As there can be wide variations in room dimensions, *reflectances* resulting from interior decoration, and floor coverings, rooms differing substantially from the examples given below, may require specific calculations.

COMMENT

Downlights and other luminaires with concentrated or narrow beam distribution, require particular care with spacing, if minimum *illuminance* criteria are to be met.

1.0.3 Refer to NZBC D1 "Access Routes", for stair tread visibility and minimum *illuminance* requirements.

Table 1: Lighting in Common Spaces Wattage Requirement (W/m²)
Paragraph 1.0.1

Luminaire type	Space category		
	Corridors (note 3)	Stair and lift lobbies (note 4)	Places of assembly (note 5)
Incandescent (plastic shade)	12	10	6
Incandescent (general diffusing enclosure)	15	12	8
Fluorescent 36 W cool white (enclosed diffusing fitting)	7	4	2
Fluorescent compact single-ended 11-16 W (enclosed diffusing fitting)	8	5	–
Discharge 50 W high pressure sodium (enclosed diffusing fitting)	5	5	–
Incandescent reflector type downlights (120 W PAR 38 flood)	–	–	6
Mercury vapour downlight (80 W coated lamp)	–	–	2

Note:

- The figures given are measurements from site tests and the wattages include the power required for control gear where it is part of the installation. Gaps in the table indicate the unavailability of a specific installation for testing.
- The figures (W/m²) are not suitable for situations where narrow beam downlights, or small numbers of high power luminaires are used.
- Data is based on a corridor 3.0 m wide and longer than 15 m, with ceiling mounted luminaires 3.0 m above floor level.

Reflectances:

Ceiling	0.7
Walls	0.5
Floors	0.1

- Data is based on a lobby area 7.0 m by 4.0 m with ceiling mounted luminaires 3.0 m above floor level.

Reflectances:

Ceilings	0.7
Walls	0.5
Floors	0.2

- Data is based on an auditorium 16 m by 21 m with a ceiling height on 5.0 m.

Reflectances:

Ceiling	0.7
Walls	0.5
Floor	0.2

Index G8/VM1 & AS1

All references to Verification Methods and Acceptable Solutions are preceded by **VM** or **AS** respectively.

Illuminance	VM1 1.0, AS1 1.0
measurement	VM1 1.0.1
minimum	AS1 1.0.3
Star tread visibility	AS1 1.0.3
Wattage required	AS1 1.0.1

